

WESTBURY

WINDOWS & JOINERY

PART Q COMPLIANT CERTIFICATE SINGLE DOOR – OPEN INWARDS

WINTECH
BUILDING ENVELOPE TESTING

Technical Report

Report No: R15501

Product Tested: Westbury Single Door – Open Inwards

Test Conducted for: Westbury Windows and Joinery Limited
46-52 Cutlers Road
Saltcoates Industrial Estate
Essex
CM3 5XJ

Standard Specified: PAS 24:2012 – Enhanced security performance requirements for door assemblies

Project No: 15501

Date of Test: 11th November 2015

Test Conducted at: Wintech Engineering Limited
Halesfield 2
Telford
Shropshire
TF7 4QH

Test Conducted by: D Adams
Laboratory Engineer

Report Compiled by: S Ward
Laboratory Apprentice

Authorised by: M Wass
Technical Director 

1. Introduction

This report describes testing of a door sample conducted at the test laboratory of Wintech Engineering Ltd on behalf of Westbury Windows and Joinery Limited in order to determine compliance with PAS 24:2012.

Wintech Engineering Ltd is accredited by the United Kingdom Accreditation Service as UKAS Testing Laboratory No. 2223

2. Summary of Results

The following summarises the results of testing carried out, in accordance with PAS 24:2012

A.3 – Security hardware & cylinder test	Pass
B.4.6 – Manual check test	Pass
B.4.4.3 – Mechanical infill test	Pass
B.4.3 – Manipulation test	Pass
B.4.5 – Mechanical loading test	Pass
B.4.4.2 – Manual infill test	Pass
B.4.4.4 – Manual cutting test	Pass
B.4.8 – Soft body impact test	Pass
B.4.9 – Hard body impact test	Pass
Overall Classification in accordance with PAS 24:2012	DKT